

GOVERNMENT OF ANDHRA PRADESH
Rural Water Supply & Sanitation Department
R.W.S. I.W.Q.M. LABORATORY, Z.P. Compound, Srikakulam.

MPLE RECEIVED FROM : The Internatinal Delhi Public School Vadada Jn,Vappangi (Rural) Srikakulam.

RECEIVED DATE: 20.03.2024

COLLECTED By : K Charan Sahu

Dist.: Srikakulam

No	Lab Ref. No.	Mandal	Name of the Gramapanchayat	Name of the Habitation	Source (BW, OW, Sch)	Location	Code	Date of Collection	Date of Testing	pH (6.5-8.5)	Electrical Conductivity micromhos/cm 200-2000M	Total Dissolved Solids 500-2000mg/lit	Total Alkalinity as CaCo3 200-600 mg/lit	Total Hardness as CaCo3 300-600 mg/lit	Fluoride as F 1.0-1.5 PPM	Chloride Cl 250-1000 mg/lit	Calcium 75-200 mg/lit	Sulphate as SO4 200-400 mg/lit	Iron as Fe 0.3 - 1.0 mg/lit	Turbidity 5-10 NTU	Magnesium 50-150 mg/lit	Nitrate as No3 45 mg/lit	Remarks
1	32	Srikakulam	Vappangi	Vappangi	RO	The Internatinal Delhi Public School Vadada Jn,Vappangi (Rural) Srikakulam.		20.03.2024	20.03.2024	7.13	235	152	36	56	0.06	25	9	5.4	0.44	0.4	8.141	21	Satisfactory

P.S. 20/03/24
Lab Chemist
RWS&S IWQM Lab
Srikakulam

B-Nannuattu Prty.

Medical Officer
P.H.C, Srikakulam Rural
Srikakulam Dist.

28/03/2024

GOVERNMENT OF ANDHRA PRADESH
Rural Water Supply & Sanitation Department
I.W.Q.M. LABORATORY, Z.P. COMPOUND, SRIKAKULAM
Report on Bacteriological Analysis of Water (Drinking)

SAMPLE RECEIVED FROM The Internatinal Delhi Public School Vadada Jn, Vappangi (Rural) Srikakulam.

Month: March

Year: 2024

Sl.No	LAB REF. NO.	NAME OF THE MANDAL	NAME OF THE GRAMPANCHAY AT	NAME OF THE HABITATION	SOURCE	LOCATION	CODE	DATE OF COLLECTION	DATE PUT TO TEST	DATE OF REPORT	M.P.N. OF Coliforms Bacteria/ 100 ml	M.P.N OF E.COLI/ 100 ml	RESULT
1	32	Srikakulam	Vappangi	Vappangi	RO	The Internatinal Delhi Public School Vadada Jn, Vappangi (Rural) Srikakulam.		20.03.2024	20.03.2024	22.03.2024	0	0	Satisfactory

R. Jayalakshi
Microbiologist
RWS IWQM Lab
Srikakulam 22/03/24